SILE LILE

AD-A206

Report No. CETHA-TE-CR-89033 Final Report

USATHAMA

U.S. Army Toxic and Hazardous Materials Agency

ECONOMIC EVALUATION OF TWO BIOLOGICAL PROCESSES FOR TREATMENT OF BALL POWDER PRODUCTION WASTEWATER

(TASK ORDER NO. 10)

February 1989 Contract No. DAAK11-85-D-0008

Prepared by:

Arthur D. Little, Inc.

Acorn Park
Cambridge, Massachusetts 02140-2390


Prepared for:

U.S. Army Toxic and
Hazardous Materials Agency
Process Development Branch
Aberdeen Proving Ground, MD 21010-5401

DISTRIBUTION UNLIMITED

89 3 31 058

DISCLAIMER NOTICE



THIS DOCUMENT IS BEST QUALITY AVAILABLE. THE COPY FURNISHED TO DTIC CONTAINED A SIGNIFICANT NUMBER OF PAGES WHICH DO NOT REPRODUCE LEGIBLY.

REPRODUCED FROM BEST AVAILABLE COPY

THIS DOCUMENT CONTAINED BLANK PAGES THAT HAVE BEEN DELETED

Final Report to
United States Army
Toxic and Hazardous
Materials Agency
February 1989

Economic Evaluation of Two Biological Processes for Treatment of Ball Powder Production Wastewater

(Task Order Number 10)


Final Report

A.A. Balasco—Program Manager

R.C. Bowen — Task Leader

R.F. Machacek

Principal Investigators



 $\int_{\mathbb{R}_{+}} \left(f(x) \right) dx$

Distribution Unlimited

🔼 Arthur D. Little, Inc.

Contract No. DAAK11-85-D 3008
Reference 54150
USATHAMA Reference CETHA-TE-CR-89033

REPORT E	OCUMENTATIO	N PAGE				Approved No. 0704-0188
1a. REPORT SECURITY CLASSIFICATION 1b. RESTRICTIVE MARKINGS						
UNCLASSIFIED 2a. SECURITY CLASSIFICATION AUTHORITY		3. DISTRIBUTION	AVALIABILITY OF	DEDOOT		
		3. DISTRIBUTION	MYMICABILLET OF	REPURI		
2b. DECLASSIFICATION / DOV/NGRADING SCHEDU		Unlimited 5. MONITORING ORGANIZATION REPORT NUMBER(S)				
4. PERFORMING ORGANIZATION REPORT NUMBE	R(S)	5. MONITORING	ORGANIZATION RE	PORT NU	MBER(S)	
Reference: 54150		CETHA-TE-C				
6a. NAME OF PERFORMING ORGANIZATION	6b. OFFICE SYMBOL (If applicable)	7a. NAME OF MO	NITORING ORGAN	IZATION		
Arthur D. Little, Inc.	, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	U.S. Army T	oxic and Ha	zardou	s Mate	erials Agend
6c. ADDRESS (City, State, and ZIP Code)		7b. ADDRESS (Cit	y, State, and ZIP C	ode)		
Acorn Park		Attn: CETH	A-TE-D			
Cambridge, Massachusetts 021	40-2390		oving Groun	d, MD	21010	0-5401
8a. NAME OF FUNDING/SPONSORING ORGANIZATION U.S. Army Toxic &	8b. OFFICE SYMBOL		INSTRUMENT IDE			MBER
Hazardous Materials Agency	CETHA-TE-D	Task Order		,U_((,00	
8c. ADDRESS (City, State, and ZIP Code)	L	10. SOURCE OF F	UNDING NUMBER	5		
Attn: CETHA-TE-D		PROGRAM ELEMENT NO.	PROJECT NO.	TASK NO.		WORK UNIT
Aberdeen Proving Ground, MD	21010-5401	CELTICIA NO.	1.0.	1	LO	
11. TITLE (Include Security Classification) Economic Evaluation of Two Bi Wastewater 12. PERSONAL AUTHOR(S)		ses for Treat	ment of Bal	1 Powe	ler Pr	oduction
A.A. Balasco, R.C. Bowen and				,	0465	COLINE
13a. TYPE OF REPORT 13b. TIME CO	87 TO 2/89	14. DATE OF REPO February		ון עליט		6
16. SUPPLEMENTARY NOTATION						
17. COSATI CODES	18. SUBJECT TERMS (
FIELD GROUP SUB-GROUP		Propellant ration • Se				
	sive-Laden Wast	tewater • 1			ewate	r (continue
ABSTRACT (Continue on reverse if necessary	and identify by block n	umber)			(on	other side)
Currently, Badger Army Ammuniti wastewater generated during the of an environmentally acceptabl	production of le treatment fact	BALL POWDER® Llitv. the U.	propellant. S. Army Tox	Beca ic and	luse o	f the lack
Materials Agency (USATHAMA)	ired to evaluate	ed technologie	es that woul	d effe	ctive.	ly treat
ball powder production wastewat Pollutant Discharge Elimination	System (NPDES)	ently, allow requirements	its dischars] to the Wi	ge (wi sconsi	thin n Riv	the Nation <mark>a</mark> er.
1	(ae cobic					
Pilot test results indicated th batch reactor (SBR) and extende	d aeration svera	e of nitrogl	lycerin (NG) shie of meet	doth	the s	equencing
continuously. When NG was pres	ent/in the hall	powder waste	water nilo	t roct	ragn	1 to charred
that NG was toxic to the biomas	$\mathbf{s}_{m{\cdot}}$ /The toxic ef	ffout of the	NG caused a	decre	age fi	n the bioma
efficiency to perform carbonace also caused further problems by	ousvoxidation, r adversely affec	nitrification cting the bac	n and denitr cteria's abi	ificat lity t	ion.	The toxici
20 DISTRIBUTION / AVAILABILITY OF ARSTRACT	RPT DTIC USERS	21 ABSTRACT SE Unclassi	CURITY CLASSIFIC	ATION		
228. NAME OF RESPONSIBLE INDIVIDUAL	CI ONC OSERS	حصور المساحد	Include Area Code) 22c. C	FFICE SY	MBOL
Patricia A. Spains		(301) 57			THA-T	
DD Form 1473, JUN 86	Previous editions are	obsolete.				OF THIS PAGE
	λ_{7}		UNCLAS	SSIFIE	0	

#18 (continued): • Aerobic Biological Oxidation • Diphenylamine Pollutants • Dibutyl-phthalate Pollutants • n-Nitrosodiphenylamine Pollutants • Capital Cost • Operating Cos

#19 (continued): form flocs, which resulted in a significant quantity of the biomass over-flowing with the effluent, and thereby decreasing the concentration of biomass in the reactor The end result of NG's toxicity was to produce an unstable biological system that could not meet NPDES requirements.

Because of NG's toxic effect and both systems' ability to meet NPDES limits in the absence of NG, preliminary full-scale designs for both extended aeration and SBR systems were prepared based on the removal of NG in a pretreatment system. These preliminary designs were then used to develop budgetary capital and operating costs to compare the economics of both biological systems. Within the range of accuracy (plus 40/minus 10%) of the budgetary estimates both systems were found to be approximately equal in cost.

The final conclusion, based on the pilot studies, conducted at Badger AAP, and the cost analysis, was that either biological system was capable of meeting NPDES limits and that both systems were equivalent on a capital and operating cost basis. The systems were also equivalent with respect to:

- System safety,
- Throughput rate,
- Reliability,
- Ease of operation, and
- · Permitting.

Consequently, based on both technical and economic merits, we conclude that either biological system is capable of treating ball powder wastewater at Badger AAP; however, the wastewater must first be pretreated for NG removal.

TABLE OF CONTENTS

			Page
List	of Ta	ables	ii
List	of F	igures	ii
EXEC	UTIVE	SUMMARY	ES-1
1.0	INTR	DDUCTION	1 · 1
2.0	SYST	EM DESCRIPTION	2 - 1
	2.2 2.3 2.4	System 100 - Collection and Equalization System 200 - pH and Nutrient Control System 300 - Extended Aeration and Aerobic Digestion System 400 - Sequencing Batch Reactor and Aerobic Digestion	2 - 1 2 - 1 2 - 4
3.0	2.5 COST	System 500 - Sludge Dewatering and Control Building ESTIMATION AND ECONOMIC EVALUATION	2 - 7 3 - 1
	3.2	Approches to Cost Estimation Capital Investment Operating Cost/Economic Evaluation	3 - 1 3 - 1 3 - 1
4.0	CONC	LUSIONS AND RECOMMENDATIONS	4 - 1
5.0	REFE	RENCES	5 - 1
APPE	NDIX .	A	A-i

LIST OF TABLES

<u> Table No.</u>		Page
1.1	Design Basis for Full-Scale Biological Treatment System at Badger AAP	1-3
1.2	Preliminary Design Summary	1-5
3.1	Capital Investment Costs for Extended Aeration and Sequencing Batch Reactor Systems	3 - 2
3.2	Annual Operating Cost for Extended Aeration with Nonhazardous Waste	3 - 3
3.3	Annual Operating Cost Sequencing Batch Reacator with Nonhazardous Waste	3-4
3.4	Annual Operating Cost for Extended Aeration with Hazardous Waste	3 - 6
3.5	Annual Operating Cost for Sequencing Batch Reactor with Hazardous Waste	3 - 7

LIST OF FIGURES

Figure No	<u>o.</u>	Page
2.1	100 - Collection and Equilization Basin	2 - 2
2.2	200 - pH and Nutrient Control	2 - 3
2.3	300 - Extended Aeration and Aerobic Digestion	2 - 5
2.4	400 - Sequencing Bauch Reactors and Aerobic Digestion	2 - 6
2.5	500 - Sludge Dewatering	2 - 8

EXECUTIVE SUMMARY

Currently, Badger Army Ammunition Plant (AAP) has no facility other than lagoons for treating wastewater generated during the production of BALL POWDER® propellant*. Because of the lack of an environmentally acceptable treatment facility, the U.S. Army Toxic and Hazardous Materials Agency (USATHAMA) desired to evaluate technologies that would effectively treat ball powder production wastewater and, subsequently, allow its discharge [within the National Pollutant Discharge Elimination System (NPDES) requirements] to the Wisconsin River.

Pilot test results indicated that in the absence of nitroglycerin (NG) both the sequencing batch reactor (SBR) and extended aeration systems were capable of meeting NPDES requirements continuously. When NG was present in the ball powder wastewater, pilot test results showed that NG was toxic to the biomass. The toxic effect of the NG caused a decrease in the biomass efficiency to perform carbonaceous oxidation, nitrification and denitrification. The toxicity also caused further problems by adversely affecting the bacteria's ability to form flocs, which resulted in a significant quantity of the biomass overflowing with the effluent, and thereby decreasing the concentration of biomass in the reactor. The end result of NG's toxicity was to produce an unstable biological system that could not meet NPDES requirements.

Because of NG's toxic effect and both systems' ability to meet NPDES limits in the absence of NG, preliminary full-scale designs for both extended aeration and SBR systems were prepared based on the removal of NG in a pretreatment system. These preliminary designs were then used to develop budgetary capital and operating costs to compare the economics of both biological systems. Within the range of accuracy (plus 40/minus 10%) of the budgetary estimates, both systems were found to be approximately equal in cost.

The final conclusion, based on the pilot studies, conducted at Badger AAP, and the cost analysis, was that either biological system was capable of meeting NPDES limits and that both systems were equivalent on a capital and operating cost basis. The systems were also equivalent with respect to:

- System safety,
- Throughput rate,
- Reliability,
- Ease of operation, and
- Permitting.

Consequently, based on both technical and economic merits, we conclude that either biological system is capable of treating ball powder wastewater at Badger AAP; however, the wastewater must first be pretreated for NG removal.

^{*}BALL POWDER propellant is a registered trademark of Olin Corporation.

1.0 INTRODUCTION

Currently, Badger Army Ammunition Plant (AAP) has no facility other than lagoons for treating wastewater generated during the production of BALL POWDER® propellant*. Because of the lack of an environmentally acceptable treatment facility, the U.S. Army Toxic and Hazardous Materials Agency (USATHAMA) desired to evaluate technologies that would effectively treat ball powder production wastewater and, subsequently, allow its discharge [within the National Pollutant Discharge Elimination System (NPDES) requirements] to the Wisconsin River.

Arthur D. Little, Inc. was contracted by USATHAMA under Contract No. DAAK11-85-D-0008 to evaluate the technical and economic feasibility of technologies for treating ball powder propellant wastewater. In a previous task (Task Order Number 11/Subtask 11.1) entitled "Ball Powder Production Wastewater Biodegradation Support Studies," Arthur D. Little designed, installed, and operated two biological oxidation pilot plants to evaluate extended aeration and sequencing batch reactor (SBR) systems.

- Determine the ability of each system to treat ball powder production wastewater [with and without nitroglycerin (NG)] and meet anticipated NPDES requirements;
- (2) Determine the toxic effect, if any, of ball powder propellant wastewater (both with and without NG) on the biological systems; and
- (3) Develop preliminary design criteria for use in the ultimate engineering, design, and costing of a full-scale wastewater treatment system.

During the evaluation of the pilot test data, we determined that NG exhibited a toxic effect on the biomass (regardless of the type system) which negatively impacted the system's performance resulting in the treated wastewater exceeding the anticipated NPDES requirements for most parameters [biochemical oxygen demand (BOD), total suspended solids (TSS), and N-nitrosodiphenylamine (NDPA)]. In additional pilot plant tests, however, we determined that both the extended aeration and SBR systems were capable of treating ball powder wastewater without NG and meeting anticipated NPDES requirements. Thus, the recommendation was made to install a pretreatment system for the removal of NG prior to the wastewater being introduced to the full-scale biological treatment system. Since our contract (Scope of Work) with USATHAMA did not include the testing and/or evaluation of NG pretreatment systems, we have made the assumption, for this cost analysis, that an effective NG pretreatment system already exists at Badger AAP. Therefore, we have excluded any capital and operating costs which would be associated

^{*}BALL POWDER propellant is a registered trademark of Olin Corporation.

with such a pretreatment system from this cost analysis. Consequently, we have used the data from the pilot-scale testing (without NG) to develop the preliminary design criteria (Tables 1.1 and 1.2) which was used in preparing the required capital and operating cost estimates.

The objective of this task (Task Order Number 10), entitled "Computerization and Application of a Standard Cost Evaluation Method," under USATHAMA Contract No. DAAK11-85-D-0008, was to conduct an economic comparison of both extended aeration and SBR full-scale wastewater treatment systems in order to allow USATHAMA personnel to make a direct comparison between them. To meet this objective, we developed process flow diagrams, equipment lists, equipment specifications, operating requirements, and associated capital and operating costs for both systems.

TABLE 1.1

DESIGN BASIS FOR FULL-SCALE BIOLOGICAL TREATMENT SYSTEM AT BADGER AAP

Ball Powder Production

Anticipated Throughput: 1.0 - 3.0 million 1b ball powder/month Wastewater Generated: 1.0 - 3.0 million gal wastewater/day

Wastewater Inlet Characterizat.on

COD 1,400 mg/L TSS 30 mg/L TDS 3,500 mg/L Ethyl Acetate 340 mg/L Collagen 300 mg/L DBP 1.1 mg/L NDPA 1.9 mg/L NG 8 mg/L
TDS 3,500 mg/L Ethyl Acetate 340 mg/L Collagen 300 mg/L DBP 1.1 mg/L NDPA 1.9 mg/L NG 8 mg/L
Ethyl Acetate 340 mg/L Collagen 300 mg/L DBP 1.1 mg/L NDPA 1.9 mg/L NG 8 mg/L
Collagen 300 mg/L DBP 1.1 mg/L NDPA 1.9 mg/L NG 8 mg/L
DBP 1.1 mg/L NDPA 1.9 mg/L NG 8 mg/L
NDPA 1.9 mg/L NG 8 mg/L
NG 8 mg/L
1 2 /7
$NO_2 - N$ 1.3 mg/L
NO ₃ -N 1.3 mg/L NH ₄ -N 14 mg/L TKN 65 mg/L
TKN 65 mg/L
pH 7

Anticipated NPDES Limits

pН	6.0 - 9.0
BOD	45 mg/L (daily)
	30 mg/L (avg)
Total Phathalates	3.0 ug/L
Total Nitrosoamines	3.0 ug/L
TSS	50 mg/L
TDS	no limit assumed
NO ₃ - N	50 mg/L
NO ₃ -N SO ₄ DO ⁴	no limit assumed
DO4	6-8 mg/L

TABLE 1.1 (Continued)

DESIGN BASIS FOR FULL-SCALE BIOLOGICAL TREATMENT SYSTEM AT BADGER AAP

Optimum Operating Conditions

F:M ratio Extended aeration SBR	0.11 day 1 0.14 day
Dissolved oxygen uptake rate • Extended aeration • SBR	0.27 mg/L/min 0.33 mg/L/min
Concentration of biomass in leactor (MLSS) • Summer months • Winter months	3,500 mg/L 4,500 mg/L
Concentration of settled biomass (MLSS)	10,000 mg/L
Growth rate of biomass	0.3 lb biomass/lb BOD
Aerobic Digestion Optimum retention time Biomass reduction Concentration of settled biomass	15 days 3 40* 10,000 mg/L
Percent solids from belt filter	20%

Source: Arthur D. Little, Inc.

TABLE 1.2

PRELIMINARY DESIGN SUMMARY

Biological Reactor	Extended Aeration	SBR
Reactor Volume Number of Reactors Hydraulic Retention Time Biomass Growth Biomass Retention Time Nitrogen Supplied Phosphorus Supplied	7.3 million gal 2 58 hr 7,130 lb/day 30 days 0 lb/day 250 lb/day	5.7 million gal 3 • 46 hr 7,130 lb/day 23 days 0 lb/day 250 lb/day
Aeration System		
Biological Oxygen Requirement Air Flow Rates (STP)	980 lb/hr 4,000 ft /min	1,200 lb/hr 4,880 ft ³ /min
Clarifier		
Percent Recycle Clarifier Area Number of Clarifiers Dimensions of each Clarifier • Diameter • Depth	77% 7,500 ft ² 2 70 ft 15 ft	NA NA NA NA
Aerobic Digestor		
Reactor Volume Retention Time Sludge to Digestor	1.3 million gal 15 days 86,000 gal/day	1.3 million gal 15 days 86,000 gal/day
Sludge Dewatering and Disposal		
Sludge Dewatered Sludge to Disposal	51,600 gal/day 21,500 lb/day	51,600 gal/day 21,500 lb/day

NA - Not Applicable

Source: Arthur D. Little, Inc.

2.0 SYSTEM DESCRIPTION

We have prepared preliminary process designs for both a full-scale extended aeration system and a full-scale SBR system based on the design criteria shown in Table 1.1. The major assumption in our design was that the wastewater had been pretreated for removal of NC prior to its introduction to either biological system. For ease of review, the design has been divided into five systems:

- System 100 Collection and Equalization
- System 200 pH and Nutrient Control
- System 300 Extended Aeration and Aerobic Digestion
- System 400 Sequencing Batch Reactor and Aerobic Digestion
- System 500 Sludge Dewatering and Control Building

Systems 100, 200, and 500 are common to both the SBR and extended aeration systems, and only the design and costing of Systems 300 and 400 differentiate the two cases.


2.1 System 100 - Collection and Equalization

Figure 2.1 shows the process flow diagram for the collection and equalization of the wastewater. The design is straightforward with the ball powder propellant wastewater entering two clarifiers (100-1 and 100-2) for preliminary clarification. These two clarifiers already exist at Badger AAP and, therefore, would not have to be purchased or installed. The clarified wastewater then flows into a sump where it is pumped to a large equalization basin to even out fluctuations in wastewater composition. The equalization basin (100-7) is designed to hold one day's flow at the maximum flow rate of 3.0 MGD. The basin is to be lined first with clay and then a Hypalon® liner to prevent wastewater percolation into underlying soil. The wastewater is then pumped from the basin to pH and nutrient control (System 200).

2.2 System 200 - pH and Nutrient Control

The pilot studies indicated that there was sufficient nitrogen in the wastewater to provide for all biomass requirements for such without the need for an additional source; however, it also indicated that the wastewater did not have a sufficient supply of phosphorous. The nutrient system, therefore, uses phosphoric acid (H_3PO_4) to supply the additional phosphorous required (Figure 2.2).


In the pilot studies, we found that the pH of the wastewater averaged 7.0 with a range of 6.5 to 7.5; therefore, there was no need for a pH control system. However, because a pH outside the optimum range (5.0-8.0) for biological systems could adversely affect the biomass, a pH control system was added as a precautionary measure. In cases where the pH was in the proper range, the wastewater feed would bypass the pH control system. In the rare instance where pH is outside the optimum range, the valtewater would be directed to the pH control system where



Source: Arthur D. Little

100 - COLLECTION AND EQUALIZATION BASIN

FIGURE 2.1



200 - PH AND NUTRIENT CONTROL Source: Arthur D. Little

FIGURE 2.2

either sulfuric acid (H_2SO_4) or sodium hydroxide (NaOH) could be added to adjust the pH. After the pH control system, the wastewater would be pumped to either the SBR or extended aeration treatment system.

2.3 System 300 - Extended Aeration and Aerobic Digestion

In the case of extended aeration, upon exiting the pH control system, the wastewater is divided into two streams and is continuously fed to both biological oxidation basins (Figure 2.3). Each basin (300-1) is equipped with three two-speed aerators (300-2) which can be used to vary the relative sizes of the aeration and anoxic zones and to give the operators of the basins the 3-to-1 turndown ratio that Badger AAP requires. Two variable height weirs (300-3) also facilitate turndown in throughput and serve as the points for overflow to the two clarifiers (300-5).

The treated wastewater and suspended biomass flow to the clarifiers for separation into treated effluent and concentrated biomass sludge. Both clarifiers are 70 ft in diameter and 14 ft deep with geodesic domes covering them to prevent freezing in the winter. From the bottom of the clarifier, the concentrated biomass is either recycled to the head of the oxidation basins or wasted to the aerobic digestor. The clarified effluent flows by gravity from the clarifiers to the chlorinator (300-15), where it is disinfected prior to its discharage to the river.


The sludge to be wasted is pumped to an aerobic digestor (300-9), where the biomass and any remaining biodegradable organics are oxidized, the sludge mass and volume are reduced, and the sludge is conditioned for further processing. The aerobic digestion system was included for two reasons:

- (1) To insure that the bacteria had sufficient time to degrade any priority pollutants [NDPA and dibutylphthalate (DBP)] in the biomass, in order to increase the potential for delisting the sludge; and
- (2) To reduce the total amount of biomass that needed to be disposed of as either a hazardous or nonhazardous waste.

The waste sludge from the digestor is then pumped to sludge dewatering (System 500) for removal of water to produce a dewatered sludge for disposal.


2.4 System 400 - Sequencing Batch Reactor and Aerobic Digestion

In the case of the SBR (Figure 2.4), the wastewater from the pH and nutrient control system is directed to the SBR basin (one of three) currently in the fill phase. The operating sequence of the basins (400-1) would be such that one of the three basins would always be filling; this insures a continuous flow of wastewater to the SBR system. Upon completion of the fill cycle, the SBR would run through



300 - EXTENDED AERATION AND AEROBIC DIGESTION FIGURE 2.3

2-5



400 - SEQUENCING BATCH REACTORS AND AEROBIC DIGESTION

the react, settle, decant, and sludge wasting phases. The treated effluent would then be disinfected with chlorine (400-14) prior to its discharge to the environment.

The excess sludge is pumped to an aerobic digestor (400-8) where, as in the extended aeration system, the biomass and any remaining biodegradable organics are oxidized, the sludge mass and volume are reduced, and the sludge is conditioned for further processing. Similarly, the aerobic digestion system was added for two reasons:


- (1) To insure that the bacteria had sufficient time to degrade any priority pollutants [NDPA and dibutylphthalate (DBP)] in the biomass, in order to increase the potential for delisting the sludge; and
- (2) To reduce the total amount of biomass that needed to be disposed of as either a hazardous or nonhazardous waste.

The waste sludge from the digestor would then be pumped to sludge dewatering (System 500) to remove water and produce a dewatered sludge for disposal.

2.5 System 500 - Sludge Dewatering and Control Building

The waste sludge is retained in the aerobic digestor for 15 days where the sludge volume is reduced by approximately 40%. After the 15-day retention time, the sludge is pumped to the sludge dewatering system (Figure 2.5). Prior to the actual filtration, a flocculant (500-1) is added to the sludge for improved drainage of the water from the sludge solids. The sludge is then loaded on the belt filter (500-3). The filtrate is collected and recycled back to the biological treatment system; the solids are collected and disposed of on-site as a nonhazardous waste.

The assumption is that Badger AAP will be able to petition the Environmental Protection Agency (EPA) to have the sludge delisted as a nonhazardous waste. The results of the pilot program suggest that delisting the sludge may be possible because of the low concentrations of NDPA and DBP components in the sludge. Another indication that Badger AAP may be able to delist the sludge is the fact that Radford AAP currently operates a biological treatment system for wastewater with similar chemical compositions generated in their single- and double-base operations and has had the sludge produced in this treatment facility delisted. With the sludge delisted, Radford AAP land disposes of the sludge on-site in a landfill; Badger AAP may be able to do this as well.



SYSTEM 500 - SLUDGE DEWATERING

FIGURE 2.5

Artiur D Little

3.0 COST ESTIMATION AND ECONOMIC EVALUATION

3.1 Approaches to Cost Estimation

The preliminary process engineering analysis and equipment sizing performed on the two biological treatment systems established the basis for estimating the capital investment and operating costs. For component or subsystem costs, we used a combination of general published cost curves, current cost estimation manuals, and budgetary quotations from equipment suppliers. We used Guthrie's Modular Factor method to convert purchased component costs to installed costs. The modular factor, specific to each type of equipment, is intended to account for all direct and indirect cost elements in placing a piece of equipment into operation. These cost elements include engineering, procurement, freight, insurance, taxes, field installation (materials and labor), contractor's fee and contingency. The specific modular factors that were used, along with an equipment list and the purchased equipment component costs, are shown by system in Appendix A.

All cost data were brought to current Fourth Quarter, 1988, by using the Chemical Engineering Plant Cost Index. All costs are budgetary in nature and have an uncertainty of plus 40/minus 10%.

Operating costs were developed based upon the operating requirements established in the mass balances and equipment sizing calculations as discussed in the previous section. Costs for operating materials were obtained from suppliers of such. Costs for labor and utilities were supplied by Badger AAP personnel.

3.2 Capital Investment

Capital investments for extended aeration and SBR systems, as summarized in Table 3.1, are \$5.5 million and \$6.0 million, respectively. In addition to the process equipment, allowances are made to include plant building, office and laboratory space, and the associated equipment for such offices and laboratories. The slightly higher (8%) capital cost for the SBR system is the result of the higher cost associated with constructing three separate concrete basins for the SBR system in contrast to the two basins for extended aeration. The additional costs for the clarifiers required for the extended aeration system brought its capital cost closer to that of the SBR system, but SBR system capital cost remained slightly higher.

3.3 Operating Cost/Economic Evaluation

Operating requirements and their associated costs for the Badger AAP wastewater treatment system (using both biological treatment technology options) are shown in Tables 3.2 and 3.3 for extended aeration and SBR, respectively. The operating costs are grouped into two categories, variable costs and fixed costs. Variable costs include costs for utilities, chemicals, operating labor, and on-site disposal of the

Table 3.1

Capital Investment Costs for
Extended Aeration and Sequencing Batch Reactor Systems

		Extended Aeration	SBR
System	Description	(1988 Dollars)	(1988 Dollars)
100	Collection and Equalization Basin	\$485,000	\$485,000
200	pH and Nutrient Control	\$330,040	\$330,000
300	Extended Aeration and Aerobic Digestion	\$4,105,000	0\$
400	Sequencing Batch Reactors and Aerobic Digestion	0\$	\$4,580,000
200	Sludge Dewatering System and Control Building	\$640,000	\$640,000
	Total Capital Investment	\$5,560,000	\$6,035,000

Source: Arthur D. Little, Inc.

Table 3.2 Annual Operating Cost for Extended Aeration with Nonhazardous Waste

<u>Item</u>	Units/ Year		t/Unit Dollars)	Annual Cost (1988 Dollars)
Variable Costs				
Raw Materials				
•Phosphoric Acid	17.5 Ton	\$64.50		\$1,130
•Sulfuric Acid	2 Ton	\$48.00		\$100
•Sodium Hydroxide	2 Ton	\$190.00		\$380
•Polymer	3 Ton	\$3,000.00	/I on	\$9,000
Labor				
•Operating	4,160 hours	\$13.50	/hour	\$56,200
•Sup€r∵isory	2,080 hours	\$21.00	/hour	\$43,700
Utilities				
•Electricity	9,408,000 kwh	\$0.04	/kwh	\$376,300
•Fuel	4,000 Gal	\$0.49	/Gal	\$2,000
•Water	350,000 Gai	\$30.00	/MMGal	\$10
Sludge Disposal (On-site as a Nonhazardous Waste)	3750 Tons	\$20.00	/Ton	\$75,000
	Subtotal Variable Costs			\$ 563,820
Fixed Costs				
Maintenance				
·Labor and Materials	4% of Capital Investment			\$222,400
Plant Overhead	105% of Labor and Mainten	ance		\$338,400
Depreciation	10% of Capital Investment			\$556,100
Taxes and Insurance	2% of Capital Investment			\$111,200
	Subtotal Fixed Costs			\$1,228,100
Total Operating Cost				\$1,791,920

Source: Arthur D. Little, Inc.

Arthur D Little

Table 3.3
Annual Operating Cost for
Sequencing Batch Reactor with Nonhazardous Waste

!tem	Units/ Year		t/Unit Dollars)	Annual Cost (1988 Dollars)
Variable Costs				
Raw Materials				
Phosphoric Acid	17.5 Ton	\$64.50	/Ton	\$1,130
•Sulfuric Acid	2 Ton	\$48.00	/Ton	\$100
 Sodium Hydroxide 	2 Ton	\$190.00	/Ton	\$380
•Polymer	3 Ton	\$3,000.00	/Ton	\$9,000
Labor				
•Operating	4,160 hours	\$13.50	/hour	\$56,200
•Supervisory	2,080 hours		/hour	\$43,700
Utilities				
Electricity	11,390,000 kwh	\$0.04	/kwh	\$455,600
•Fuel	4,000 Gal	\$0.49	/Gal	\$2,000
•Water	350,000 Gal	\$30.00	/MMGal	\$10
Sludge Disposal (On-site as a Nonhazardous Was	3,750 Tons te)	\$20.00	/Ton	<u>\$75,000</u>
	Subtotal Variable Costs			\$ 643,120
Fixed Costs				
Maintenance				
•Labor and Materials	4% of Capital Investment			\$241,500
Plant Overhead	105% of Labor and Mainte	nance		\$358,400
Depreciation	10% of Capital Investmen	nt		\$603,600
Taxes and Insurance	2% of Capital Investment			\$120,700
	Subtotal Fixed Costs			\$1,324,200
Total Operating Cost				\$1,967,320

Source: Arthur D. Little, Inc.
Arthur D Little

waste biomass as a nonhazardous waste. Fixed costs include items such as plant overhead, maintenance (materials, labor and supplies), depreciation, taxes and insurance. The operating costs for both the SBR and extended aeration are similar with the extended aeration again being slightly (about 10%) less. The differences stem largely from lower charges related to lower capital costs for the extended aeration system and less electrical energy usage by this system.

As discussed in Section 2.5, the assumption has been made that the sludge generated in either biological treatment system will be delisted and can, therefore, be disposed of as a nonhazardous waste. However, if delisting is not possible, the cost of disposing of the sludge as a hazardous waste will be very expensive (\$1,000/ton vs \$20/ton). This case is shown in Tables 3.4 and 3.5 for extended aeration and SBR, respectively. It is obvious from these tables that the annual operating cost increases (for either system) by nearly 300% if the sludge is considered a hazardous waste. This is due solely to the vast increase in cost for disposing of the sludge as a hazardous waste (\$3.75 million/year) in contrast to a nonhazardous waste (\$75,000/year).

Table 3.4 Annual Operating Cost for Extended Aeration with Hazardous Waste

Item	Units/ Year	Cost/L (1988_D		Annual Cost (1988 Dollars)
Variable Costs				
Raw Materials				
Phosphoric Acid	17.5 Ton	\$64.50	/Ton	\$1,130
•Sulfuric Acid	2 Ton	\$48.00	/Ton	\$100
 Sodium Hydroxide 	2 Ton	\$190.00	/Ton	\$380
•Polymer	3 Ton	\$3,000.00	/Ton	\$9,000
Labor				
Operating	4,160 hours	\$13.50	/hour	\$56,200
•Supervisory	2,080 hours		/hour	\$43,700
Utilities				
•Electricity	9,408,000 kwh	\$0.04	/kwh	\$376,300
•Fuel	4,000 Gal	•	/Gal	\$2,000
•Water	350,000 Gal		/MMGai	\$10
Sludge Disposal (Off-site as a Hazardous Waste)	3750 Tons	\$1,000.00	/Ton	\$3,750,000
	Subtotal Variable Costs			\$4 ,238,820
Fixed Costs				
Maintenance				
·Labor and Materials	4% of Capital Investment			\$222,400
Plant Overhead	105% of Labor and Mainten	ance		\$338,400
Depreciation	10% of Capital Investment			\$556,100
Taxes and Insurance	2% of Capital Investment			\$111,200
	Subtotal Fixed Costs			\$1,228,100
Total Operating Cost				\$5,466,920

Source: Arthur D. Little, Inc.

Arthur D Little

Table 3.5 Annual Operating Cost for Sequencing Batch Reactor with Hazardous Waste

ltem	Units/ Year	Cos (1988 [VUnit Pollars)	Annual Cost (1988 Dollars)
Variable Costs				
Raw Materials				
Phosphoric Acid	17.5 Ton	\$64.50	/Ton	\$1,130
 Sulfuric Acid 	2 Ton	\$48.00	/Ton	\$100
 Sodium Hydroxide 	2 Ton	\$190.00	/Ton	\$380
•Polymer	3 Ton	\$3,000.00	/Ton	\$9,000
.ahor				
Operating	4,160 hours	\$13.50	/hour	\$56,200
•Supervisory	2,080 hours	\$21.00	/hour	\$43,700
Utilities				
Electricity	11,390,000 kwh	\$0.04	/kwh	\$455,600
•Fuel	4,000 Gal	\$0.49	/Gal	\$2,000
•Water	350,000 Gal	\$30.00	/MMGal	\$10
Sludge Disposal (Off-site as a Hazardous Waste)	3,750 Tons	\$1,200.00	/Ton	\$3,750,000
	Subtotal Variable Costs			\$4,318,120
Fixed Costs				
Maintenance				
·Labor and Materials	4% of Capital Investment			\$241,500
Plant Overhead	105% of Labor and Mainter	nance		\$358,400
Depreciation	10% of Capital Investment	t		\$603,600
Taxes and insurance	2% of Capital Investment			\$120,700
	Subtotal Fixed Costs			\$1,324,200
Total Operating Cost				\$5,642,320

Source: Arthur D. Little, Inc.
Arthur D Little

4.0 <u>DISCUSSION AND CONCLUSIONS</u>

Pilot test results indicated that in the absence of NG both the SBR and extended aeration systems were capable of meeting NPDES requirements continuously. When NG was present in the ball powder wastewater, pilot test results showed that NG was toxic to the biomass. The toxic effect of the NG caused a decrease in the biomass efficiency to perform carbonaceous oxidation, nitrification and denitrification. The toxicity also caused further problems by adversely affecting the bacteria's ability to form flocs, which resulted in a significant quantity of the biomass overflowing with the effluent, and thereby decreasing the concentration of biomass in the reactor. The end result of NG's toxicity was to produce an unstable biological system that could not meet NPDES requirements.

Because of NG's toxic effect and both systems' ability to meet NPDES limits in the absence of NG, preliminary full-scale designs for both extended aeration and SBR systems were prepared based on the removal of NG in a pretreatment system. These preliminary designs were then used to develop budgetary capital and operating costs to compare the economics of both biological systems. Within the range of accuracy (plus 40/minus 10%) of the budgetary estimates, both systems were found to be approximately equal in cost.

The final conclusion, based on the pilot studies, conducted at Badger AAP, and the cost analysis, was that either biological system was capable of meeting NPDES limits and that both systems were equivalent on a capital and operating cost basis. The systems were also equivalent with respect to:

- System safety,
- Throughput rate,
- Reliability,
- Ease of operation, and
- Permitting.

Consequently, based on both technical and economic merits, we conclude that either biological system is capable of treating ball powder wastewater at Badger AAP; however, the wastewater must first be pretreated for NG removal.

5.0 REFERENCES

- Balasco, A.A. and R.C. Bowen, et al., "Ball Powder Production Wastewater Pilot-Scale Biodegradation Support Studies (Final Report)," prepared for USATHAMA under Contract No. DAAK11-85-D-0008 by Arthur D. Little, Inc., Cambridge, MA, February 1989.
- Balasco, A.A. and R.C.Bowen, et al., "Ball Powder Production Wastewater Pilot-Scale Biodegradation Support Studies - with Nitroglycerin (Final Report)," prepared for USATHAMA under Contract No.DAAK11-85-D-0008 by Arthur D. Little, Inc., Cambridge, MA, February 1989.
- 3. Aasheim, S.E., and B.W. Newbry, "Sludge Stabilization," Water Pollution Control Federation, 1985.
- 4. Smith, L.L., Conversation with R.C. Bowen about Disposal of Radford Army Ammunition Plant's Biological Sludge, January 1989.
- 5. Hall, R.S., J. Matley and K.J. McHaughton, <u>Chemical Engineering</u>, pp 80-116, April 5, 1982.
- 6. "Richardson Process Plant Estimation Standards," Richardson Engineering Services, Inc., April 1988 Edition.
- 7. "Building Construction Cost Data," Robert Snow Means Company, Inc., 1982.
- 8. Guthrie, K.M., "Process Plant Estimation Evaluation and Control," 1974.

Appendix A

- Table A.1 Equipment List/Specifications/ Cost for Collection System and Equilization Basin System 100
- Table A.2 Equipment List/Specifications/ Cost for pH and Nutrient Control System 200
- Table A.3 Equipment List/Specifications/ Cost for Extended Aeration and Aerobic Digestion — System 300
- Table A.4 Equipment List/Specifications/ Cost for Sequencing Batch Reactor and Aerobic Digestion — System 400
- Table A.5 Equipment List/Specifications/ Cost for Sludge Dewatering and Control Building System 500

Table A.1 Equipment List/Specifications/ Cost for Collection System and Equilization Basin — System 100

NEW INSTALLED COST	;	;	\$24,840	\$24,840	\$52,728	\$20,280	\$361,560	\$484,248
MODULAR	:	:	1.38	1.38	3.38	3.38	1.36	•
NEW TOTAL COST	į	1	\$18,000	\$18,000	\$15,600	\$6.000	\$262,000	\$319,600
NIMBER OF UNITS	-	-	-		N	N	-	
COST	Existing	Existing	\$18,000 s)	\$18,000 sj	\$7,800	\$3,000	\$262,009	
DESCRIPTION	Single Base Clarifier	Double Base Clarifier	Single Base Sump (in Ground Concrete Tank, 25,000 Gallons)	Double Base Sump (In Ground Concrete Tank, 25,000 Gallons)	Single Base Pump (35 hp - 1,800 GPM)	Double Base Pump (6 hp - 280 GPM)	Equalization Basin (Clay Lined with Rubber (Hypalon) liner, 3 Million Gallons)	SYSTEM 100 SUBTOTALS
ITEM	100-1	100-2	100-3	100-4	100-5	100-6	130-7	

Source: Arthur D. Little, Inc.

Table A.2
Equipment List/Specifications/ Cost for pH and Nutrient Control — System 200

COST	88	006	006	006	090	020	050	909	320	125	488	109
RISTALL	\$59,488	\$16,900	\$16,900	\$16,900	\$28,050	\$28,050	\$28,050	\$27,600	\$43,350	\$3,825	\$59,488	\$328,601
MODULAR	3.38	3.38	3.38	3.38	2.55	2.55	2.55	1.38	2.55	2.55	9.3 8	
TOTAL	\$17,600	\$5,000	\$5,000	\$5,000	\$11,000	\$11,000	\$11,000	\$20,000	\$17,000	\$1,500	\$17,600	\$121,700
NUMBER OF UNITS	N .	8	α	8	-	-	-	N	-	-	~	
LANT	\$8.800	\$2,500	\$2,500	\$2,500	\$11,000	\$11,000	\$11,000	\$10,000	\$17,000	\$1,500	\$8,600	
DESCRIPTION	Waste Feed Pump (40 hp - 2000 GPM)	Phosphoric Acid Metering Pump (Steinless Steel, Variable Speed, 5 GPM)	Sulturic Acid Metering Pump (Stainless Steel, Variable Speed, 5 GPM)	Caustic Metering Pump (Stainless Steel, Variable Speed, 5 GPM)	Phosphoric Acid Slovage Tank (Fiberglass Tank, 5,000 Gallons)	Suffuric Acid Storage Tank (Fiberglass Tank, 5,000 Gallons)	Caustic Storage Tank (Fiberglass Tank, 5,000 Gallons)	Inline Mixer	pH Control Tank (Baffled, Fiberglass Tank, 10,000 Gallons)	Agitator for pH Control Tank (2 hp - Turbine Blade)	Neuralized Waste Pump (40 hp - 2000 GPM)	SYSTEM 200 SUBTOTAL
TEM	200-1	200-2	200-3	200-4	200-5	200-6	200-7	200-8	200-9	200-10	200-11	

Source: Arthur D. Little, Inc.

Table A.3
Equipment List/Specifications/ Cost for Extended Aeration and Aerobic Digestion — System 3

	Extended Aeration and Aerobic Digestion -	Aerobic I	Digestion	n — System 300	n 300	
ITEM	DESCRIPTION	UNIT	NUMBER OF UNITS	TOTAL	MODULAR	NSTALLED COST
300.1	Biological Oxidation Ditch (In-Ground Concrete Tank, 3.7 Million Gallons, Including: Excavation, Materials, Labor, and Backlilling)	\$607,000	N	\$1,214,000	1.38	\$1,675,320
300-2	Two Speed Mechanical Aerators (150 hp Aerators and Auxilary Equipment)	\$102,900	ro	\$617,400	1.38	\$352,012
300-3	Variable Height Wek	\$10,000	~	\$20,000	1.38	\$27,600
300-4	Claritier Mechanism (70 foot Diamete, Including: Scum Skimmete, Weirs, and Baffles)	\$46,500	N	\$93,000	1.38	\$128,340
300-5	Claritier Tank (in-Ground Concrete Tank, 430,000 Gallons, Including: Excavation, Materials, Labor, and Backliffing)	\$104,000	N	\$208,000	1.38	\$287,040
300-6	Clarifier Waste Studge Pump (5 hp)	\$2,400	~	54 ,800	3.38	\$16,224
300-7	Geodesic Doms (70 foot diamenter)	\$65,000	ev.	\$170,000	1.38	\$234,600
300-8	Dipostors Blower Assembly (100 hp Aerators & Auxiliary Equipment)	\$31,000	69	\$93,000	1.38	\$128,340
300-9	Aerobic Digestor Tank (In-Ground Concrete Tank, 1.3 Million Gallions, Inctuding: Excavation, Materials, Labor, and Backlilling)	\$263,200	-	\$283,200	1.38	\$390,816
300-10	Aerobic Digestor Assembly (Including: 60 hp DDM Miter, Floating Decant Pump, Control Panel, 4 Aeration Headers)	\$80,000	-	\$80,000	1.38	\$110,400
300-11	Waste Studge Pump (5 hp)	\$2,400	8	\$4,800	3.38	\$16,224
300-12	Digastor Effluent Return Pump (5 hp)	\$2,400	8	44 ,800	3.38	\$16,224
300-13	Chlorine Storage Tarik (Spherical Steel Tank - 200 psi, 5,000 Gallons)	\$30,000	~	\$60,000	2.57	\$154,200
300-14	Chlorine Metering Pump (Stainless Steel, Variable, 5 GPM)	\$2,500	8	\$5,000	3.38	\$16,900
300-15	Chlorinator (Ho 'tontal Pressure Tank 200 pei, 5,006 Gallons)	\$18,000	-	\$18,000	2.87	\$51,660
	SYSTEM 300 SUBTOTAL			\$2,876,000		\$4,105,900

Table A.4
Equipment List/Specifications/ Cost for Sequencing Batch Reactor and Aerobic Digestion — System 400

اہ		6													اد
INSTALLED	\$1,018,440	\$1,533,870	\$641,700	\$89,232	\$39,546	\$364,320	\$110,400	\$390,816	\$128,340	\$16,224	\$25,688	\$154,200	\$16,900	\$51,660	\$4,581,336
MODULAR	1.38	1.38	1.38	3.38	3.38	1.38	1.38	1.38	1.38	3.38	3.38	2.57	3.38	2.87	
TOTAL COST	\$738,000	\$1,111,500	\$465,000	\$26,400	\$11,700	\$264,000	000'09\$	\$283,200	\$93,000	\$4,800	\$7,600	\$60,000	\$5,000	\$18,000	\$3,168,200
NUMBER OF UNITS	၈	e	၈	၈	ო	М	-	-	n	QI	O)	N	N	-	
COST	\$246,000	\$370,500	\$155,000	\$8,800	006,63	\$88,000	\$80,000	\$283,200	\$31,000	£2,400	\$3,800	\$30,000	\$2,500	\$18,000	
DESCHIPTION	SBR Assembly (40 hp DDM Mixer, Decanter, Diffuser	Drop Assemblies, Influent Baffles, Controls) SBR Tærk (In-Ground Concrete Tank, 1.9 Million Gallons, Including: Excavation, Meterials, Labor and Backfilling)	Geodesic Dome (140 foot diameter)	Effluent Pump (40 hp - 200 GPM)	Waste Studge Pump (10 hp - 60 GPM)	SBR Blower Assembly (300 hp Aerators and Digestors)	Aerobic Digestor Assembly (Including: 60 hp DDM Mixer, Floating Decart Pump, Control Panel, 4 Aeration Headers)	Aerobic Digestor Tank (in Ground Concrete Tank, 1.3 Million Galfons, Induding: Excavation, Materials, Labor, and Backlilling)	Aerobic Digestor Blower Assembly (100 hp Aerators and Auxilary Equipment)	Aerobic Digestor Pump (5 hp)	Digestor Effluent Return Pump (5 hp)	Chlorine Storage Tank (Spherical Steel Tank - 200 psi, 5,000 Gallons)	Chlorine Metering Pump (Stainless Steel, Variable, 5 GPM)	Chlorinator (Horizontal Pressure Tank - 200 psi, 5,000 Gallons)	SYSTEM 400 SUBTOTAL
TEN	400-1	400-2	400-3	4-00+	400-5	400-6	400-7	400-8	6-00+	400-10	400-11	400-12	400-13	400-14	

Table A.5
Equipment List/Specifications/ Cost for Sludge Dewatering and Control Building — System 500

ITEM	DESCHIPTON	UNIT	NUMBER OF LIMITS	TOTAL	MODULAR	NSTALLED
500-1	Polymer System (300 gal Stank, 1/2 hp Mixer, Dry Polymer Educic, and Variable Speed Cavity Pump)	\$18,500	-	\$18,500	1.38	\$25,530
500-2	Filter Feed Pump (7.5 hp - 100 gpm)	\$13,500	0	\$27,000	1.38	\$37,260
500-3	Bett Filter (1 meter bett press, air compressor and wash water pump)	\$96,500	-	\$96,500	1.33	\$133,170
₹-909	Recycle Wash Water Pump (5 hp)	\$2,400	cv	\$4,800	3.80	\$18,240
500-5	Laboratory/Control Building (3,000 sq ft Facility)	\$310,000	-	\$310,000	1.38	\$427,800
	SYSTEM 500 SUBTOTALS			\$456,800		\$642,000

DISTRIBUTION LIST

Defense Technical Information Center Cameron Station Alexandria, Virginia 22314	12
Defense Logistics Studies Information Exchange U.S. Army Logistics Management Center Fort Lee, Virginia 23801	2
Commander U.S. Army Toxic and Hazardous Materials Agency Attn: CETHA-TE-D Aberdeen Proving Ground, Maryland 21010-5401	2
Commander U.S. Army Toxic and Hazardous Materials Agency Attn: AMXTH-TE-D Aberdeen Proving Ground, Maryland 21010-5401	14